



OIL FILLED TRANSFORMER RECONDITIONING PROCEDURES

Minor Reconditioning:

- Clean all parts
- Clean, prime and paint exterior
- Replace hand-hole gasket, bushing gaskets, and where applicable, external tap changer gasket with new gaskets, as necessary
- All gauges will be cleaned and inspected.
- Electrically test transformer

Full Reconditioning:

- All minor reconditioning procedures above, plus the following:
- Untank and dismantle, as necessary
- Oven bake core and coil, as necessary to remove moisture

1) Transformers will be reconditioned upon receiving a written purchase order. This classification of repair is minor and covers transformers that do not require rewinding of the coils. Areas of reconditioning are performed on an "as needed" basis. Transformers may be reconditioned in one or more of the ways above.